

## BRACKET HEATING

This building has two boilers in the basement mechanical room which are controlled on a sliding scale that is enabled at 58°F and circulates water at 100°F and as it gets colder outside the water in the in the system gets hotter so at 5°F the water temperature is 190°F, water temperature is linear between these two set points. This outdoor reset is sufficient to maintain the building set points and not waste energy that is not needed to support the building.

The heater in each room has a manually adjusted heat control valve that can be set by the occupant to adjust the heat for their own thermal comfort within the range set by the College Energy Management System. Heat is only available when the zone sensor calls for it so the room control should be set to a mid-range setting until the room has stabilized, usually a 24 hour period and then adjust the room control for cooler or warmer. Each room has the proper amount of radiation to keep the space at 65°F regardless of the outside temperature. The day set point is 68°F and is scheduled from 6:30 a.m. to 12:00 a.m. while the night setback is 65°F for the rest of the time. This schedule and temperature are set by the College Energy Management System.

Before reporting a heat issue, please check the following:

1. Position of room control; 0=OFF (cold), 8=ON (heat)
2. Air flow restricted by furniture; 4" minimum clearance for heat convection.
3. Windows closed and properly latched.
4. Added heat source by room control; Lamps, Computers, Small refrigerators all produce heat that will affect the room sensor operation.